

## ANCHORAGE FIRE DEP MENT Municipality of Anchorage **FIRE INSPECTION NOTICE**



FIN: 16-1252-RV

90

Date of Inspection:

12/30/2015

**Building Information** 

Re-inspection Date:

1/29/2016

Occ: R2

Re-inspection schedule:

Area: 20,000-49,999 SF

7 14 30

Sprinkler: No

Inspector name and Phone:

Bldg type Residential

Rita Venta

Inspection Type G

# Units Apartments more than 20

Inspection Fee:

Inspec. time: 1.00

Bldg name: Busi name:

Royal Suite Lodge (2 Bldg) **Royal Suite Apartments** Site Address: 3811MINNESOTA21

**Royal Suite Apartments** 

Inspection status:

Thomas Yoon, General Manager

**Progress** 

3811 Minnesota Anchorage, Ak 99503

Inspection

## Fire Inspection Comments:

**Clear Comment** 

- North building mechanical room/maintenance shop- hot water heater in shop/needs to have fire rated wall/door & frame for required 1 hr separation from shop
- **End of List**

Recd Corrective Service Reports from Yukon for several corrections on Status 2 Fire Alarm. System now Status 4. DB testing completed. All units meet 65.

- Fire extinguishers current and compliant
- Recd verification form verifying all units have CO detectors. Smoke detectors on sounder bases tied to fire alarm system
- PO
- Telecon 10/29/15 questions about the required separation in Item #1. Wants to meet with contractor at job site.
- **End of List** 8