Accessibility Audit of Polling Places 2018 - Priority 1: Parking, Signs, Curb-cuts, Accessible Route to Entrance and Entrance with recommendations for election day

Date of Audit	Precinct/Location	NOTES
3/27/2018	101 Asbury United Methodist Church - 1305 Troupe St.	No van sign, curb cut at corner missing
3/27/2018	102 Crawford Ave. Baptists Church - 507 Crawford Ave.	Parking at front; broken curb; ramped entrance on Walker St at back; Needs door buzzer or door stop;
3/27/2018	103 Dyess Park - 902 James Brown Blvd	No van sign; parking at back; entrance at front near curb cut on public sidewalk; Needs a ma on front door threshold
5/2/2018	104 Eastview Recreation Center - 644 Aiken St	No van sign; door speed needs adjusted
3/27/2018	105 Mt. Calvary Baptist Church - 1260 Wrightsboro Rd	No access aisles or parking signs; need paint and painted access aisles; Main/ADA entrance at is at front near curb cut on public sidewalk
12/9/2016	106 Julian Smith Casino - 2200 Broad St.	No van signs, repaint space and access aisle
12/9/2016	107Julian Smith Casino- 2200 Broad St.	See 106
4/25/2018	108 Covenant Presbyterian Church - 3131 Walton Way	No van signs; sign missing at side door
12/9/2016	109 May Park- 622 4th St	No van sign; ramp into access aisle
4/25/2018	111 Heal Complex- Paine College - 1255 Druid Park	Lacks directional sign at main non-accessible entrance
12/9/2016	112 May Park 622 4th St	See 109
5/3/2018	114 Bernie Ward Community Center - 1941 Lumpkin Rd	Repaint parking and add access aisles where missing; lacks van accessible sign; adjust door speed
5/4/2018	115 Southside Baptist Church - 3612 Mike Padgett Highway	Lacks parking signs but they are painted w/ access aisles

Date of Audit	Precinct/Location	NOTES
4/30/2018	201 Augusta Deliverence Evangelistic Church - 2028 Roosevelt Dr.	Parking lacks paint and van sign
5/3/2018	202 Bernie Ward Community Center - 1941 Lumpkin Rd.	See 114
3/27/2018	204 Asbury United Methodist Church - 1305 Troupe St	See 101
4/30/2018	207 Mt. Vernon Baptist Church - 1930 Olive Rd	Non-compliant door hardware; prop door open or put buzzer on door; lacks parking sign
1/9/2018	208 Minnick Park - 1850 Kissingbower Rd.	Paint parking including access aisle; lacks van sign; raise signs; move curbs; door threshold is > 1/2 inch and need short ramp added
5/2/2018	210 Augusta Aquatics Center - 3157 Damascus Rd.	No access aisle for car spaces; lacks van signs; raise low signs

4/25/2018 301 Covenant Prebyterian Church - 3131 Walton Way See 108 4/25/2018 302 Augusta Univ Christenberry Fieldhouse - 3109 Marvin Vanover Dr 5/2/2018 303 Augusta Aquatics Center - 3157 Damascus Rd See 210 3/27/2018 304 Asbury United Methodist Church - 1305 Troupe St. See 101 4/25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 4/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 4/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	302 Augusta Univ Christenberry Fieldhouse - 3109 Marvin Vanover Dr noted that driveway is 1/3 mi long and sloped and not pedestrian friendly See 210 See 210 303 Augusta Aquatics Center - 3157 Damascus Rd See 210 See 101 Parking at secondary building lacks signs 305 First Baptist Church of Augusta - 3500 Walton Way See 305 2/9/2016 307 Julian Smith Casino - 220 Braod St See 106 308 First Baptist Church of Augusta - 3500 Walton Way See 306 2/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	Precinct/Location	NOTES
noted that driveway is 1/3 mi long and sloped and not pedestrian friendly noted that driveway is 1/3 mi long and sloped and not pedestrian friendly See 210 3/27/2018 304 Asbury United Methodist Church - 1305 Troupe St. See 101 4/25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 4/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	noted that driveway is 1/3 mi long and sloped and not pedestrian friendly noted that driveway is 1/3 mi long and sloped and not pedestrian friendly 2/2/2018 303 Augusta Aquatics Center - 3157 Damascus Rd See 210 2/27/2018 304 Asbury United Methodist Church - 1305 Troupe St. See 101 2/25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 2/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 2/29/2016 307 Julian Smith Casino - 220 Braod St See 106 2/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 2/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	301 Covenant Prebyterian Church - 3131 Walton Way	See 108
3/27/2018 304 Asbury United Methodist Church - 1305 Troupe St. See 101 4/25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 4/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	27/2018 304 Asbury United Methodist Church - 1305 Troupe St. See 101 25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 2/9/2016 307 Julian Smith Casino - 220 Braod St See 106 2/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 2/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	302 Augusta Univ Christenberry Fieldhouse - 3109 Marvin Vanover Dr	3 of 4 entrances are accessible with ramped curbs; access aisles < 8ft wide; lacks van sign noted that driveway is 1/3 mi long and sloped and not pedestrian friendly
4/25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 4/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	25/2018 305 First Baptist Church of Augusta - 3500 Walton Way Parking at secondary building lacks signs 25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 See 106 See 106 25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 See 306 See 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs Lac	303 Augusta Aquatics Center - 3157 Damascus Rd	See 210
4/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	/25/2018 306 First Baptist Church of Augusta - 3500 Walton Way See 305 2/9/2016 307 Julian Smith Casino - 220 Braod St See 106 /25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 /25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	304 Asbury United Methodist Church - 1305 Troupe St.	See 101
12/9/2016 307 Julian Smith Casino - 220 Braod St See 106 4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	2/9/2016 307 Julian Smith Casino - 220 Braod St See 106 /25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 /25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	305 First Baptist Church of Augusta - 3500 Walton Way	Parking at secondary building lacks signs
4/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306	/25/2018 308 First Baptist Church of Augusta - 3500 Walton Way See 306 /25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	306 First Baptist Church of Augusta - 3500 Walton Way	See 305
	/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	307 Julian Smith Casino - 220 Braod St	See 106
4/25/2018 309 Sharon Baptist Church - 3434 Sharon Rd Lack van signs	<u> </u>	308 First Baptist Church of Augusta - 3500 Walton Way	See 306
	/25/2018 310 Providence Baptist Church - 3850 Wrightsboro Rd Lack van signs; no curb ramp from access aisle	309 Sharon Baptist Church - 3434 Sharon Rd	Lack van signs
4/25/2018 310 Providence Baptist Church - 3850 Wrightsboro Rd Lack van signs; no curb ramp from access aisle		310 Providence Baptist Church - 3850 Wrightsboro Rd	Lack van signs; no curb ramp from access aisle
4/25/2018			301 Covenant Prebyterian Church - 3131 Walton Way 302 Augusta Univ Christenberry Fieldhouse - 3109 Marvin Vanover Dr 303 Augusta Aquatics Center - 3157 Damascus Rd 304 Asbury United Methodist Church - 1305 Troupe St. 305 First Baptist Church of Augusta - 3500 Walton Way 306 First Baptist Church of Augusta - 3500 Walton Way 307 Julian Smith Casino - 220 Braod St 308 First Baptist Church of Augusta - 3500 Walton Way 309 Sharon Baptist Church - 3434 Sharon Rd

Date of Audit	Precinct/Location	NOTES
4/26/2018	401 Gracewood Community Center - 2309 Tobacco Rd	Lacks van sign; relocate 2 of the 4 spaces; repaint spaces and aisles; adjust door speed; hand rail and ramp present but not compliant (effective construction date of 1973)
5/3/2018	402 McDuffie Woods Community - 3431 Old McDuffie Rd	Lacks van sign; move 2 ADA spaces to front entrance
5/8/2018	404 Wildwood Christian Church - 2627 Tobacco Rd	Lacks parking sign and needs repainted; curb ramp needs maintanence
4/26/2018	405 Diamond Lakes Regional Park - 4335 Windsor Spring Rd	Robert Howard Community Ctr Bldg Parking access aisles need repainted; van space needs moved to the space nearest the entrance
4/26/2018	406 Jamestown Community Center - 3647 New Karleen Rd	Lacks van sign; move ADA spaces and put access aisle between them at ramp landing; ramp landing needs maintanence;

Date of Audit	Precinct/Location	NOTES
4/30/2018	501 New Zion Missionary Baptist Church - 3237 1/2 Deans Bridge Rd	Lacks parking and van sign but has painted spaces and access aisle; has directional sign
5/8/2018	502 Trinity CME Church - 2930 Glenn Hills Dr.	Lacks van sign and needs repainted; access aisle narrow
12/8/2016	503 Henry H. Brigham Community Center - 2463 Golden Camp Rd	lacks van signs; parking ramp is improperly installed; some spaces need repainted and moved over at back/side door
5/8/2018	504 Bayvale Baptist Church - 2240 Bayvale Rd.	Lacks access aisles and van sign; signs low; entrance ramp is functional but not compliant
5/4/2018	506 Stevens Creek Church/SouthPoint Campus - 3358 Peach Orchard Rd	Parking painted but lacks signs
4/25/2018	507 Augusta Univ Christenberry Fieldhouse -3129 Marvin Vanover Dr	See 302
5/8/2018	509 Wildwood Christian Church - 2627 Tobacco Rd	See 404

Date of Audit	Precinct/Location	NOTES
5/8/2018	601 East Central Regional HospGracewood - Magnolia Dr., Bldg 22 - Gym	Needs painted and sign is low; curb ramp and driveway are uneven and poorly repaired
5/4/2018	603 Burns Memorial United Methodist Church - 2372 Lumpkin Rd	Parking lacks signs but is well painted;
5/4/2018	604 Southside Baptist Church - 3612 Mike Padgett Hwy	See 115
5/4/2018	605 Stevens Creek Church/Southpoint Campus - 3358 Peach Orchard Rd	See 506
4/26/2018	607 Gracewood Community Center - 2309 Tobacco Rd	See 401
5/4/2018	608 Pine Hill Baptist Church - 4233 Old Waynesboro Rd	Lacks parking signs and access aisle; ADA entrance has non-complaint door hardware - door needs to be propped open or have buzzer

Date of Audit	Precinct/Location	NOTES
5/7/2018	701 Aldersgate United Methodist Church - 3185 Wheeler Rd	Lacks van sign; sign too low
5/7/2018	702 St. Marks United Methodist Church - 2367 Washington Rd.	Lacks parking signs; ADA directional and drop-off signs present; access aisles narrow or missing
5/7/2018	703 National Hills Baptist Church - 2725 Washington Rd	Parking signs low or missing; lacks van sign
5/2/2018	706 Warren Road Recreation Center - 300 Warren Rd	Add van sign; connect all spaces to accessible route
5/7/2018	707 Vineyard Church - 3126 Parrish Rd	Lacks van sign; no curb ramp at access aisle
5/2/2018	708 Warren Road Recreation Center - 300 Warren Rd	See 706
5/7/2018	709 Vineyard Church - 2126 Parrish Rd	See 707

Date of Audit	Precinct/Location	NOTES
5/8/2018	801 Blythe City Hall -294 Church St	Parking sign too low;Ramp handrail non-compliant
5/8/2018	801B Blythe City Hall - 294 Church St	See 801
5/3/2018	802 McBean Community Center - 1155 Hephzibah-McBean Rd	Lacks Van sign; adjust door speed of main door
4/26/2018	803 Jamestown Community Center - 3647 New Karleen Rd	See 406
5/8/2018	804 Hephzibah Carroll Community Center - 4977 Windsor Spring Rd	Parking and access aisle needs repainted; sign needs replaced; lack van sign; curb rampneeds maintance
5/8/2018	804H Hephzibah Carroll Community Center - 4977 Windsor Spring Rd	See 804
5/4/2018	805 Southside Baptist Church - 3612 Mike Padgett Hwy	See 115
5/4/2018	806 Pine Hill Baptist Church 4233 Old Waynesboro Rd	See 608
4/26/2018	807 Jamestown Community Center - 3647 New Karleen Rd	See 803
5/4/2018	808 Cross Creek High School - 3855 Old Waynesboro Rd	Lacks Van sign
4/29/2018	809 Diamond Lakes Regional Park - 4335 Windsor Spring Rd	See 405
5/8/2018	810 Hephzibah Carroll Community Center - 4977 Windsor Spring Rd	See 804